

PUBLIC HEALTH SERVICES GOVT. OF MAHARASHTRA

DISTRICT PUBLIC HEALTH LABORATORY, NASHIK.

Civil Hospital Campus Trimbak road, Nashik - 422001

E-mail: dphlnasik@gmail.com

Phone:- 0253-2570613

REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sender's Name :- NEW GRACE ACADEMY.

Address :- Ekta Nagar, Near Ankay Society, Borgad, Mhasrul, Nashik.

Sender's Letter No. & Date :- 29/05/2024 333/2024

Laboratory Reference No. :- 1523

Date of Sample Collection :- 29/05/2024

Date of Arrival at Laboratory :- 29/05/2024

Date of Commencing Examination:- 29/05/2024

Sr. No.	Particulars of Water Samples	Results of Analysis			Remark
		Most Probable Number of bacteria Per 100 ml.			
		Coliforms	Thermotolerant coliforms	<i>E.coli</i>	
1	Nashik Municipal Corp. Water Sample	0	0	0	<u>Potable</u>
Receipt No :- 5145557		Fee Rs. :- 940/-		Date:- 29/05/2024	
Note :- Result mentioned above is/are of submitted sample only.					


Outward No:-

2608/24

Date:-

6 JUN 2024

वैद्यकीय अधिकारी
श. प्रा. आ. केंद्र
मखमलाबाद, पंचवटी,
ना. म. न. पा. नाशिक


Junior Scientific Officer
District Public Health Laboratory,
Nashik.



Maharashtra Government
DISTRICT PUBLIC HEALTH LABORATORY, NASHIK

Office Phone No.:- 0253 – 2570613

Email Id:- dphlnasik@gmail.com

Office: - Junior Scientific Officer District Public Health,
Laboratory, Civil Hospital Campus, Trimbak Road, Nashik -
422 001.

NO. DPHL/NSK/WC/ W-122/ 2801 /2024

Date:- 20 / 6 /2024

Health Services

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection- ----- Date of receipt -29/05/2024 Date of Examination-29/05/2024 & onwards
Letter No.- 333/NGA/2024 dated-29/05/2024


Analytical results in mg/litre (except pH& turbidity)


Sr. No.	Name of Test	Results	BIS Specification 10500:2012	
			Desirable limits	Permissible limits
	Source	Boarwell water	-----	-----
01	Physical appearance	Clear, colourless	-----	-----
02	Odour	odourless	Agreeable	Agreeable
03	p ^H	07.60	6.5 to 8.5	No relaxation
04	Turbidity (NTU)	0.34	1.0	5.0
05	Chlorides	51.98	250	1000
06	Total Hardness	320.00	200	600
07	Total alkalinity	316.80	200	600
08	Total dissolved solids	441.00	500	2000
09	Fluoride	0.17	1.0	1.5
10	Iron	0.21	0.3	No relaxation
11	Nitrates	31.00	45	No relaxation
12	Permanent hardness	03.20	-----	-----

Remark 01:-Sample No.01 contains total hardness and total alkalinity more than desirable limit. However, if there is no other alternative source available nearby then this water source can be used for drinking purpose only after proper treatment, disinfection and ascertaining its bacteriological quality frequently or regularly.

Forwarded with compliments to:
New Grace Academy
Ekata nagar,near Akshay Society,
Borgad, Mhasrul, Nashik.

R.No.-5145557, Rs.600/-, Dt-29/05/2024


Junior Scientific Officer
District Public Health Laboratory,
Nashik.


वैद्यकीय अधिकारी
श. प्रा. आ. केंद्र
मखमलाबाद, पंचवटी,
ना. म. न. पा. नाशिक